

ANALYTICAL REPORT

Mr. Richard Tyler
MILBANK MANUFACTURING INC
1400 E. Havens Street
Kokomo, IN 56901-3188

11/27/2000

Job Number: 00.06261

Page 1 of 3

Enclosed are the Analytical Results for the following samples submitted to TestAmerica, Inc. Indianapolis Division for analysis:

Project Description: WASTEWATER ANALYSIS

| Sample Number | Sample Description | Date Taken | Time Taken | Date Received |
|------------------|--------------------|---------------|---------------|------------------|
| 280972 | WEEKLY - ZINC ONLY | 11/09/2000 | 15:30 | 11/13/2000 |

TestAmerica, Inc. certifies that the analytical results contained herein apply only to the specific samples analyzed.

TestAmerica Incorporated-Indianapolis Division is in compliance with the National Environmental Laboratory Accreditation Program (NELAP) Standards.

Reproduction of this analytical report is permitted only in its entirety.

MIL0003725

ANALYTICAL REPORT

Mr. Richard Tyler
MILBANK MANUFACTURING INC
1400 F. Havens Street
Kokomo, IN 56901-3188

11/27/2000

Job No.: 00.06261

Page 2 of 3

Date Received: 11/13/2000

Job Description: WASTEWATER ANALYSIS

| Sample Number / Sample I.D. | Sample Date/ | Analyst | Reporting | | |
|-----------------------------|-----------------------|------------------|----------------------|-----------|--------|
| Parameters | Wet. Wt. Result. Flag | Units | Date & Time Analyzed | Method | Limit |
| 280972 | WEEKLY - 7INC ONLY | 11/09/2000 15:30 | | | |
| Zinc, ICP | <0.020 | mg/L | out 11/21/2000 05:56 | EPA 200.7 | <0.020 |

Page 3 of 3

KEY TO ABBREVIATIONS

- < Less than; when appearing in the result column, indicates analyte not detected at or above the Reporting Limit.
- % Percent: To convert ppm to %, divide result by 10,000. To convert % to ppm, multiply the result by 10,000.
- *
- Indicates the Reporting Limit is elevated due to insufficient sample volume.
- mg/l Part per million: Concentration in units of milligrams of analyte per liter of aqueous sample.
- ug/L Part per billion: Concentration in units of micrograms of analyte per liter of aqueous sample.
- mg/kg Part per million: Concentration in units of milligrams of analyte per kilogram of non-aqueous sample.
- ug/kg Part per billion: Concentration in units of micrograms of analyte per kilogram of non-aqueous sample.
- a Indicates the sample concentration was quantitated using a diesel fuel standard.
- b Indicates the analyte of interest was also found in the method blank.
- c Sample resembles unknown Hydrocarbon.
- dw When indicated, the result is reported on a dry weight basis. The contribution of the moisture content in the sample has been subtracted when calculating the concentration.
- d1 Indicates the analyte has elevated Reporting Limit due to high concentration.
- d2 Indicates the analyte has elevated Reporting Limit due to matrix.
- e Indicates the reported concentration is estimated.
- g Indicates the sample concentration was quantitated using a gasoline standard.
- h Indicates the sample was analyzed past recommended holding time.
- i Insufficient spike concentration due to high analyte concentration in the sample.
- j Indicates the reported concentration is below the Reporting Limit.
- k Indicates the sample concentration was quantitated using a kerosene standard.
- l Indicates an MS/MSD was not analyzed due to insufficient sample. An LCS / LCS Duplicate provided for precision.
- m Indicates the sample concentration was quantitated using a mineral spirits standard.
- o Indicates the sample concentration was quantitated using a motor oil standard.
- p Indicates the sample was post spiked due to sample matrix.
- q Indicates MS/MSD exceeded control limits. The associated sample may exhibit similar matrix bias. All other quality control indicators are in control.
- r Indicates the sample was received past recommended holding time.
- u Indicates the sample was received improperly preserved and/or improperly contained.
- uj Indicates the result is below the Reporting Limit and is considered estimated.

MIL0003727

TestAmerica, Inc. Indianapolis Division
6964 Hillisdale Ct., Indianapolis, IN 46250
Phone: (317) 842-4261 FAX: (317) 842-4286

TO: Mr. Richard Tyler
COMPANY: MILBANK MANUFACTURING INC

FROM: Josh Dutton
COMPANY: Indianapolis Division
PHONE: (317)842-4261

SENT ON: Mon Nov 27 16:05:02 2000

NUMBER OF PAGES (INCLUDING COVER): 4

COMMENTS:

PLEASE CALL NUMBER ABOVE IF FAX TRANSMISSION IS INCOMPLETE.

This material is intended only for the use of the individual or entity to whom it is addressed, and may contain information that is privileged and confidential. If you are not the intended recipient, or the employee or agent responsible for delivering this material to the intended recipient, you are hereby notified that any dissemination, distribution or copying of this communication is strictly prohibited. If you have received this communication in error, please notify us immediately by telephone at the following toll free number 1-800-485-0204.

MIL0003728

DATE: NOVEMBER 9TH,2000

MILBANK MANUFACTURING COMPANY

| TIME | METER READING | INITIALS |
|-------|---------------|----------|
| 7:30 | 117240 | SLH |
| 8:00 | 117430 | SLH |
| 8:30 | 117600 | SLH |
| 9:00 | 117790 | SLH |
| 9:30 | 117950 | SLH |
| 10:00 | 118170 | SLH |
| 10:30 | 118310 | SLH |
| 11:00 | 118460 | SLH |
| 11:30 | 118650 | SLH |
| 12:00 | 118830 | SLH |
| 12:30 | 119040 | SLH |
| 1:00 | 119210 | SLH |
| 1:30 | 119420 | SLH |
| 2:00 | 119610 | SLH |
| 2:30 | 119790 | SLH |
| 3:00 | 119960 | SLH |
| 3:30 | 120070 | SLH |

Please test for the following highlighted
PART I

EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS

Beginning the effective date of this permit and lasting until the expiration date, the permittee is authorized to discharge process wastewater, through discharge point # 2. Discharge through discharge point # 2 shall be limited and monitored by the permittee as specified below: (1)

Discharge Limitations

| <u>Regulated Parameter</u> | <u>Maximum for Any one Day mg/L</u> |
|----------------------------|-------------------------------------|
| Cadmium[5] | .02 |
| Total Chromium[5] | 2.0 |
| Copper[5] | 0.60 |
| Cyanide | 0.50 |
| Lead[5] | 0.10 |
| Nickel[5] | 0.80 |
| Silver[5] | 0.24 |
| Zinc[5] | 1.25 |
| Oil and Grease[6] | 100 |
| TPH[6] | (Monitor and report) |
| pH | 6-10 |
| CBOD [4] | (Monitor and report) |
| Ammonia [4] | (Monitor and report) |
| COD [4] | (Monitor and report) |
| TSS [4] | (Monitor and report) |
| Flow | N/A |
| TTO | 2.13 |
| Phenol | 0.50 |
| Molybdenum[5] | (Monitor and report) |

Monitoring Requirements

| <u>Monitoring Frequency</u> | <u>Sample Type</u> |
|-----------------------------|--------------------|
| Semi-Annual | Composite[2] |
| Semi-Annual | Composite[2] |
| Semi-Annual | Composite[2] |
| Semi-Annual | Grab |
| Semi-Annual | Composite[2] |
| Semi-Annual | Composite[2] |
| Semi-Annual | Composite[2] |
| 1 X Week | Composite[2] |
| Semi-Annual | Grab |
| Semi-Annual | Grab |
| Daily | Grab |
| 1 X Month | Composite[2] |
| 1 X Month | Composite[2] |
| 1 X Month | Composite[2] |
| 1 X Month | Composite[2] |
| Daily [3] | |
| Semi-Annual | Grab |
| Semi-Annual | Grab |
| 1 X Month | Composite[2] |

DAILY: EVERY DAY SYSTEM RUNS

1X WEEK: 1 DAY OF WEEK COMPOSITE IS TAKEN (USUALLY THURSDAY)

1X MONTH: TO BE TAKEN FIRST WEEK COMPOSITE IS TAKEN FOR THAT MONTH

SEMI-ANNUAL: TO BE TAKEN FIRST WEEK IN JUNE AND FIRST WEEK IN DECEMBER

PART I

A. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS

Beginning the effective date of this permit and lasting until the expiration date, the permittee is authorized to discharge process wastewater, through discharge point # 2. Discharge through discharge point # 2 shall be limited and monitored by the permittee as specified below: (1)

Discharge Limitations

Monitoring Requirements

| | Regulated Parameter | Maximum for Any one Day mg/L | RESULT | DATE TAKEN | Monitoring Frequency | Sample Type |
|------------------------------|---------------------|------------------------------|--------|------------|----------------------|--------------|
| Cd | Cadmium[5] | .02 | | | Semi-Annual | Composite[2] |
| Cr | Total Chromium[5] | 2.0 | | | Semi-Annual | Composite[2] |
| Cu | Copper[5] | 0.60 | | | Semi-Annual | Composite[2] |
| Ca | Cyanide | 0.50 | | | Semi-Annual | Grab |
| Pb | Lead[5] | 0.10 | | | Semi-Annual | Composite[2] |
| Ni | Nickel[5] | 0.80 | | | Semi-Annual | Composite[2] |
| | Silver[5] | 0.24 | | | Semi-Annual | Composite[2] |
| Zn | Zinc[5] | 1.25 | <0.020 | 11-9-00 | 1 X Week | Composite[2] |
| FOG | Oil and Grease[6] | 100 | | | Semi-Annual | Grab |
| 21L + GREASE HYDROCARBONS | TPH[6] | (Monitor and report) | | | Semi-Annual | Grab |
| | pH | 6-10 | | | Daily | Grab |
| | CBOD [4] | (Monitor and report) | | | 1 X Month | Composite[2] |
| Nh3 | Ammonia [4] | (Monitor and report) | | | 1 X Month | Composite[2] |
| | COD [4] | (Monitor and report) | | | 1 X Month | Composite[2] |
| | TSS [4] | (Monitor and report) | | | 1 X Month | Composite[2] |
| | Flow | N/A | | | Daily [3] | |
| * | FTO | 2.3 | | | Semi-Annual | Grab |
| | Phenol | 0.50 | | | Semi-Annual | Grab |
| Mo | Molybdenum[5] | (Monitor and report) | | | 1 X Month | Composite[2] |

ND TFO CERTIFICATION STATEMENT IN LIEU OF MONITORING ALONG WITH 40 CFR
TEGORICAL STATEMENT MUST BE SENT EVERY JUNE AND DECEMBER (SEMI-ANNUAL)

MIL0003731

FedEx USA AirbillFedEx
Tracking
Number

820974328799

1 From Please print and press hard.Date 11/10/00 Sender's FedEx
Account Number 1147-6132-0Sender's
Name stephanie hohenberger Phone (765) 452-5694Company Milbank Mfg. CompanyAddress 1400 E. Havens Street

Dept./Floor/Suite/Room

City Kokomo State IN ZIP 46901**2 Your Internal Billing Reference**

First 24 characters will appear on invoice.

3 To
Recipient's
NamePhone (317) 842-4261Company TESTAMERICA INCORPORATEDAddress 6964 HILLSDALE CT

Dept./Floor/Suite/Room

We cannot deliver to P.O. boxes or P.O. ZIP codes.

To "HOLD" at FedEx location,
print FedEx address here.City INDIANAPOLIS State IN ZIP 46250**NEW Peel and Stick FedEx USA Airbill**

See back for application instructions.

Questions? Call 1-800-Go-FedEx® (800-463-3339)Visit our Web site at www.fedex.comBy using this Airbill you agree to the service conditions on the back of this Airbill
and in our current Service Guide, including terms that limit our liability.

SN431
Pickup # 6
0215
Sender's Copy +

4a Express Package ServiceDelivery commitment may be later in some areas.
Packages up to 150 lbs.☒ **FedEx Priority Overnight**
Next business morning☐ **FedEx Standard Overnight**
Next business afternoon☐ **FedEx First Overnight**
Earliest next business morning
delivery to select locations☐ **FedEx 2Day***
Second business day☐ **FedEx Express Saver***
Third business day* FedEx Letter Rate not available
Minimum charge: One-pound rate**4b Express Freight Service**Delivery commitment may be later in some areas.
Packages over 150 lbs.☐ **FedEx 1Day Freight***
Next business day☐ **FedEx 2Day Freight**
Second business day☐ **FedEx 3Day Freight**
Third business day

* Call for Confirmation.

* Declared value limit \$500

5 Packaging☐ **FedEx Letter***☐ **FedEx Pak***☒ **Other Pkg.**
Includes FedEx Box, FedEx
Tube, and customer pkg.**6 Special Handling**☐ **Saturday Delivery**
Available for FedEx Priority
Overnight and FedEx 2Day
to select ZIP codes☐ **Sunday Delivery**
Available for FedEx Priority
Overnight to select ZIP codes☐ **HOLD Weekday**
at FedEx Location
Not available with
FedEx First Overnight☐ **HOLD Saturday**
at FedEx Location
Available for FedEx Priority
Overnight and FedEx 2Day
to select locationsDoes this shipment contain dangerous goods?
One box must be checked.☐ **No**☐ **Yes**
As per attached
Shipper's Declaration☐ **Yes**
Shipper's Declaration
not required☐ **Dry Ice**
Dry Ice, 9, UN 1845 x kg

Dangerous Goods cannot be shipped in FedEx packaging.

☐ **Cargo Aircraft Only****7 Payment Bill to:**

Enter FedEx Acct. No. or Credit Card No. below.

☐ **Sender**
Acct. No. in Section 1
will be billed.☒ **Recipient**☐ **Third Party**☐ **Credit Card**☐ **Cash/Check**FedEx Acct. No. 1158-0119-8
Credit Card No.Exp.
DateTotal Packages
1Total Weight
22#15Total Declared Value*
\$.00

*Our liability is limited to \$100 unless you declare a higher value. See back for details.

FedEx Use Only

8 Release Signature

Sign to authorize delivery without obtaining signature.

By signing you authorize us to deliver this shipment without obtaining a signature
and agree to indemnify and hold us harmless from any resulting claims.

0138920775

Rev. Date 11/99-Part #154813G-©1994-98 FedEx-PRINTED IN U.S.A. GBFE 4/00

RETAIN THIS COPY FOR YOUR RECORDS

359

MIL0003732